

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7270-0067:202

Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** Siemens Building Technologies Inc., \*Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932  
Contact: Peter Pawchak (973) 593-2662 FAX (973) 593-6652

**DESIGN:** Model FPT-11 electronic fixed temperature heat detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 135<sup>0</sup>F fixed temperature

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name or Cerberus Pyrotronics, model number, temperature rating and UL label.

**APPROVAL:** Listed as heat detector for use with separately listed compatible fire alarm control units. Intended for use with listee's Model DB-11 base (CSFM Listing No. 7300-0067:134).

\*Rev. 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 18, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager